


SFM12ADB/1/2G /6M Flow sensors







CE IEC IECEX						
Product characteristics						
Flow sensor for connection	Flow sensor for connection to evaluation units					
Threaded type	Threaded type					
Cable						
Process connection: M12 x 1						
Ambient temperature -2060 °C						
ATEX approval	ATEX approval					
Group II, category 1/2G						
Zone 0 / Zone 1						
Application						
Application		liquids and gases				
Pressure rating	[bar]	300				
Medium temperature	[°C]	-2060				
Electrical data						
Connection to control monitor		VS2000 Exi (PTB 01 ATEX 2075)				
Measuring / setting range	e					
Liquide						

Connection to control monitor		VS2000 Exi (PTB 01 ATEX 2075)		
Measuring / setting ran	ige			
Liquids				
Setting range	[cm/s]	3300		
Greatest sensitivity	[cm/s]	360		
Gases				
Setting range	[cm/s]	2002000 *)		
Greatest sensitivity	[cm/s]	200800 *)		
Accuracy / deviations				
Max. temperature gradient	nt of [K/min]	15		
Reaction times				
Response time	[s]	110		
Environment				
Protection		IP 67		

Protection			IP 67	
Tests / approvals				
Approval			MT 03 ATEX E 090 X TIIS TC17434 CEX BVS 11.0017 X	
Marking of the unit				
Shock resistance		DIN IEC 68-2-27:	40 g (11 ms)	
Vibration resistance		DIN IEC 68-2-6:	10 g (552000 Hz)	
MTTF	[Years]		8648	
Safety classification				

Safety classification



SF111A



SFM12ADB/1/2G /6M Flow sensors

Internal capacitance	[nF]	1.2	
Internal inductance	[μH]	6	
Temperature class		T4	
Mechanical data			
Process connection		M12 x 1	
Materials (wetted parts)		stainless steel 316L / 1.4404	
Housing materials		stainless steel 316L / 1.4404	
Probe length L	[mm]	12	
Installation length EL	[mm]	27	
Weight	[kg]	0.353	
Electrical connection			
Connection		TPE-S cable / 6 m; 5 x 0.34 mm²	
Max. cable length	[m]	100 (5 x 0.5mm²)	
Wiring Core colors BN brown BU blue BK black WH white GY grey		BN 1 2 2 3 VS2000 Exi 8 9	
Remarks Remarks		In principle, the type test according to 94/9/EC (ATEX) only takes atmospheric conditions (0.81.1 bar) into account. For pressures outside this range use must be assessed and approved by the user. Adhere to the operating instructions and the type test certificate. *) referred to air	
Pack quantity	[piece]	1	

ifm efector, inc. • 1100 Atwater Drive • Malvern • PA 19355 - US - SF111A - 18.04.2011